


# Operation & Maintenance Manual

## KSwordfish Series-NV2.2



**Important information:**

These instructions contain safety information, read and follow them carefully. KHJ will not accept any responsibility for injury, damage or loss which may occur due to incorrect installation, operation or maintenance

# Product Important Information

Area Classification	Class I, Division 2, Group A, B, C and D; Class II, Division 2, Group F and G.			
Protection Standards	UL 844 - Luminaires for Use in Hazardous UL 1598 - Luminaires. UL 8750 - Light Emitting Diode (LED) Equipment for Use in Lighting Products UL 1598A - Supplemental Requirements for Luminaires for Installation on Marine Vessels CSA C22.2 No. 137-M1981 - Electric Luminaires for Use in Hazardous Locations CSA C22.2 No. 250.0-08 - Luminaires CSA C22.2 No. 250.13 - Light Emitting Diode (LED) Equipment for Lighting Applications.			
Installation	NFPA70			
Certificate	20171221-E491372, 20171201-E491374			
Equipment Coding	Class I Division 2, Group A,B,C,D Class II Division 2, Group F, G UL 1598A UL 1598			
Temperature Class	Type	Class I Division 2 Group A, B, C, D	Class I Division 2 Group A, B, C, D	Class II Division 2 Group F, G
		-40°C +45°C ambient	-40°C +50°C ambient	45°C ambient
	1.2m	T5	T5	T4A
	0.6m	T6	T5	T4A
Ingress Protection	IP66			
Cable Entry	M20*1.5, M25*1.5, 3/4 NPT			
UL Mark	The UL marking of this product applies to NEC 500. The Equipment is declared to meet the provisions of the NEC 500 by reason of the UL. Type Examination and compliance with the Essential Health and Safety Requirements.			

## 01. Introduction-SwordFish series UL LED light

- This user manual covers the range of UL Swordfish series LED luminaire. These luminaires are constructed with corrosion resistant epoxy coated copper free aluminum alloy body and high impact resistance tempered glass diffuser.
- Swordfish series LED are available from 36W to 100W, providing ideal solutions for a wide range of harsh and hazardous applications.

## 02. Electrical Supplies

Size:600mm			
Voltage Range(AC)	100~277VAC		
Frequency Range(Hz)	50/60Hz		
Power Watts(W)	36W	48W	56W
Standard Current Range(A)	0.12~0.36	0.17~0.48	0.2~0.56

Size:1200mm					
Voltage Range(AC)	100~277VAC				
Frequency Range(Hz)	50/60Hz				
Power Watts(W)	36W	48W	56W	72W	100W
Standard Current Range(A)	0.12~0.36	0.17~0.48	0.2~0.56	0.25~0.72	0.36~1

## 03.General

- These instructions should be read fully and carefully before attempting to install the luminaire.  
For details of servicing operations, opening etc. see section 5.
- Copies of these instructions should be held in a safe place for future reference.  
It is the responsibly of the installer to ensure that the apparatus selected is fit for it is intended purpose and that the installation, operation and maintenance of the apparatus complies with applicable regulations, standards or codes of practice.
- Risk of electrostatic discharge:
  - a.Avoid mounting near fast moving streams of air
- The luminaire should be effectively earthed.  
Certification details on the nameplate must be verified against the application requirements before installation.
- The information in this leaflet is correct at the time of publication. The company reserves the right to make specifications changes as required without notice.
- Use in Combustible Dust Atmospheres.
  - a.De-rating of the surface temperature will be required where dust clouds may be present
  - b.Do not allow dust to accumulate in layers
  - c.Dust in layers has the potential to form ignitable clouds and to burn at lower temperatures

### 3.1 Tools

- 4 mm and 5 mm flat blade screwdriver, large cross head screwdriver and inner hexagon counter wrench, suitable spanners for installing cable gland, pliers, knife, wire stripper and cutter.

### 3.2 Mounting

- Luminaire should be installed where access for maintenance is practical and in accordance with lighting design information.  
Refer to the note in 3. concerning electrostatic charge.
- See 5 installation diagram for installation mode and method.

### 3.3 Cabling and Cable Gland

- The temperature conditions at the supply cable entry point are such that 90°C(ordinary PVC) cable can be used.
- Cable gland and stopping plug must be suitably certified.  
When installed the cable gland or stopping plug should maintain the IP rating of the enclosure IP66.
- Installation requirements are detailed in the "remarks" part of Clause 5.

### 3.4 Electrical Connections and Testing

- If any operation is to be done on any luminaire already connected to the electrical system, the luminaire must be isolated from the system.
- To access the mains terminals ,loosen the fixing screws, remove the power cover.
- The wiring diagram is detailed in 5.2.1.  
The maximum amount of insulation allowed beyond the throat of the terminal is 4mm<sup>2</sup>.
- The normal method of insulation testing is to connect Live and Neutral together and test between this point.  
However,if this is not possible luminaire can be tested with an insulation tester that complies with IEC 364 with a maximum output current of 1mA and output voltage of 500V dc.(Units damaged by incorrect insulation testing can be detected).  
Before completing the wiring, ensure that all the connections are correctly introduced into place before reassembling the luminaire.



## 04.Safety instruction




- Read this leaflet carefully before commencing to install the luminaire unit and retain it for future use. Installation can only be carried out by suitably qualified personnel.
- Check Product Important Information in this user manual to ascertain type of threaded cable entry on the luminaire. Select suitably cable glands and stopper plugs.
- The cable entry devices selected must maintain the IP rating of the luminaire.
- The incoming mains cable should not exceed a temperature rise of 20°C above the ambient conditions; select suitable cable.
- External fasteners must have a yield strength of at least MPa
- The luminaire must not be operated without all the individual LED covers in position, the IP66 rating must be maintained.



## 05.Installation method

Based on the use of the scene and actual requirements, we have designed the following installation methods for customers to choose from (including but not limited to):





**Remarks:**


- External grounding cable cross-sectional area is not less than 4mm<sup>2</sup>.
- Entries into enclosures torque of locking cable introduction device 35 N.M~40 N.M.
- Select the cable glands or plug must be suitable certified.

## 5.1 Installation decomposition


It is the responsibility of the installer to ensure that the apparatus selected is fit for its intended purpose and that the installation, operation and maintenance of the apparatus complies with applicable regulations, standards or codes of practice, whichever is appropriate.

Please refer to the following installation drawing for different installation methods.


### • 5.1.1 Wall mount/Stanchion mount(unit:mm)




### • 5.1.2 Clamp mount(unit:mm)




• 5.1.3 Ceiling mount(unit:mm)



• 5.1.4 Pendant mount(unit:mm)




• 5.1.5 Pipe mount(unit:mm)



## 5.2 Electrical Principles and Connections

In addition to referring to the relevant contents of this manual, the certified personnel who have obtained the corresponding certificate according to IEC60079-14 shall strictly comply with the requirements of IEC60079-14 when installing luminaire. When installed, ensure that the luminaire is effectively grounded (internal or external).

### • 5.2.1 Electrical Principles



### • 5.2.2 Cascade

MCB Type	Rating	36W	48W	56W	72W	100W
B	16A	5	5	5	9	8
C	16A	8	8	8	14	14

According to MCB data sheet, the qty of luminaires in one Parallel connection is calculated at 230VDC

## 06.Repairs Maintenance

Visual tests and checks should be carried out at intervals described by the appropriate regulations ,and should include the following(including but not limited to).

- Check for mechanical damage/corrosion.
- Check connections, fixings, glands and plugs.
- Check for undue accumulations of dust, dirt or moisture.
- Check for unauthorized modifications.

Periodic inspection of the enclosure seal should be checked out to ensure that the seal is sound.

If the luminaire has been subject to abnormal conditions, for example, severe mechanical impact or chemical spillage, it must be de-energised until it has been inspected by an authorized and competent person.

## 07.Cleaning of luminaire

- The complete luminaire (without disassemble) can be cleaned with neutral water solution.  
After cleaning, rinsewith clean water and wipe dry .
- It is forbidden to use any chemical or hydrocarbon solvent cleaner to clean the diffuser, otherwise serious damage may be caused.
- Please clean the luminaire once a year if it is used under dust environment.

## 08. Disposal of Material

### General

Disposal of the luminaire as waste should be carried out in accordance with national regulations. Any disposal must satisfy the requirements of the WEEE directive [2012/19/EU] and therefore must not be treated as commercial waste. The unit is mainly made from incombustible materials. The control gear contains plastic, resin and electronic components. All electrical components may give off noxious fumes if incinerated.



To comply with the Waste Electrical and Electronic Equipment directive 2012/19/EU the apparatus cannot be classified as commercial waste and as such must be disposed of or recycled in such a manner as to reduce the environmental impact.

## 09. Transportation

Weatherproof measures should be taken during transportation.

It is strictly forbidden to load and unload violently, and it is strictly forbidden to drop and roll from high altitude, so as to prevent mechanical damage.

## 10. Storage

The luminaire should be stored in ventilated, non-dropping and non-liquid warehouse at the temperature of  $-20^{\circ}\text{C}$  to  $+40^{\circ}\text{C}$  and relative humidity  $\leq 95\% \text{RH}$ .

The surroundings should be kept from corrosive gases which may damage metal and insulation.

## 11. Optional Parts

No.	Installation accessories	Part No.	Picture	Material	Weight(Kg)	QTY	Remark
1	Bracket	BR-SF-U-G		Q235	0.8	2	Ceiling Mount
2	Loop	LO-SF-U-G		Q235	1.2	2	Pendant Mount
3	Pipe Clamp	PCP-SF-U-G		Q235	1.8	2	Pipe clamp
4	Stanchion bracket	SBT-SF-U-G		Q235	2.6	2	Stanchion mount Wall mount (1200mm)
5	Clamp mount	CM-SF-U-G		Q235	3	2	Clamp mount (1200mm)
6	Stanchion bracket	SBT-SF-U-G-T5		Q235	3.4	2	Stanchion mount Wall mount (600mm)
7	Clamp mount	CM-SF-U-G-T5		Q235	3.8	2	Clamp mount (600mm)



**Contact**

SHENZHEN KHJ SEMICONDUCTOR LIGHTING CO., LTD.

**Web: [www.khjled.com](http://www.khjled.com)**

Address: 4-5 Floor, Building 1, Chuangxin industrial park, Xintian community, Guanlan, Longhua new district, Shenzhen, China.

Tel: +86-755-82949977  
E-mail: [khjledsales@khj.cn](mailto:khjledsales@khj.cn)

Fax: +86-755-82949800  
Web: [www.khjled.com](http://www.khjled.com)